

Certificate

On 27th July 2005 Eurofins Product Testing A/S received a sample of a floor covering with the name

Allegro xf Tarkett

The emissions were tested according to the AgBB-scheme and guidelines of the DIBt (AgBB - Committee for Health-related Evaluation of Building Products, DIBt – German Institute for Building Technology). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1, see the test report no. 214453-71-181/en.

Evaluation of the test result according to AgBB guidelines:

- Carcinogenic substances were not detectable after 3 and after 28 days.
 - The sum of VOC ("TVOC") after 3 days was below the limit of 10.000 µg/m³.
 - The sum of VOC ("TVOC") after 28 days was below the limit of 1.000 µg/m³.
 - The sum of SVOC after 28 day was below the limit of 100 µg/m³.
 - After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m³. This value R was below the limit of 1.
 - The sum of VOC without LCI-value after 28 days was below the limit of 100 µg/m³.
 - Formaldehyde after 28 days was below the limit of 120 µg/m³.
-

The tested product complies with the requirements of DIBt (June 2004) in combination with the NIK values from AgBB (September 2005) for use in the indoor environment.

12th March 2009



Thomas Neuhaus
Head of product emission test centre



Marianne Hansen
M.Sc. (Chemistry)

Eurofins Product Testing A/S
Smedeskovvej 38
DK-8464 Galten / Denmark

Tel +45 70 22 42 66
Fax +45 70 22 42 55